



RE-ROOF REQUIREMENTS

THESE REQUIREMENTS APPLY TO BUILDING PERMITS SUBMITTED ON OR AFTER JANUARY 1, 2017

BUILDING DIVISION REQUIREMENTS

A permit is required for all re-roof installations and repairs of more than 100 square feet prior to tear off of the existing roof or any repairs.

Following is a listing of the general requirements for permit applications based on the 2016 California Building Code, 2016 California Residential Code, 2016 California Fire Code, 2016 California Energy Efficiency Standards) and the Sunnyvale Municipal Code. This brochure is intended to provide general information, contact the Building Safety Division for any questions or additional information.

General Information

- The Planning Division requires that the existing quality of roof material be maintained on all re-roofs. For example, if replacing an existing 30-year composition roof, a minimum of 30-year composition shall be installed. For the purposes of this requirements, a tile or shake roof is considered to be equivalent quality to a 40-year composition. (SMC 19.80.030)
- All new roofing material installed shall have a minimum of a Class B fire rating. (SMC 16.16.090)
- Replacement, recovering, or recoating of low-sloped roofs (2:12 pitch and less) on existing non-residential buildings are to be cool roofs and the product packaging shall be labeled as compliant with the Cool Roof Rating Council (CRRC). (CEC 10-113 and 150.2(b)1(H))
- The manufacturer's installation specifications shall be provided at the job site for the building inspector. (CBC 102.4 and CRC R102.4)
- For torch-applied roofing systems, a minimum of one portable fire extinguisher shall be available on the roof and within 30 feet of the where the hot work is performed. (CFC 3504.2.6)

Flashing (CBC 1507 and CRC R905.2.8 - R905.2.8.4)

Provide roof flashing at all wall and roof intersections, gutters, and where there is a change in the roof slope or direction around roof openings. Flashing shall be a minimum 26 gauge corrosion-resistant galvanized metal.

Drip Edge (CBC 1507.2.9.3 and CRC R905.2.8.5)

Provide a drip edge at eaves and gables of asphalt shingle roofs. Adjacent pieces of the drip edge shall be overlapped a minimum of 2 inches. The drip edge shall extend ¼ inch below the roof sheathing and a minimum of 2 inches up the roof deck. The drip edge shall be mechanically fastened to the roof deck at a maximum of 12 inches with approved fasteners. The underlayment shall be installed over the drip edge along the eaves, and under the drip edge at gables (rake edges). Shingles can be flush with the drip edge if allowed by the manufacturer.

Attic Ventilation (CBC 1203.2 and CRC R806.2)

Provide cross ventilation at all attic and enclosed rafter spaces. The net free ventilation shall be a minimum ratio of 1:150 of the area or space ventilated (e.g. 1 square foot of ventilation for each 150 square feet of attic space). This can be reduced to 1:300 when 40% to 50% of the vents are located not more than 3 feet below the ridge or highest point and the remaining vents are eave or cornice vents.

Underlayment Materials for Low Sloped Roofs (CBC 1507 and CRC R905.1.1)

For roof slopes between 2:12 and 4:12, two layers of underlayment material shall be applied. A minimum of 19 inch wide strip of underlayment felt shall be applied parallel with and starting at the eaves,

fastened sufficiently to hold in place. Starting at the eave, 36 inch wide sheets of underlayment shall be applied overlapping successive sheets 19 inches, fastened sufficiently to hold in place.

Roofs Exceeding 7.5 lbs./Square Foot

New roofs that exceed a total weight of 7.5 lbs/SF (including sheathing and roofing material) may require additional roof framing and support. Information about the existing roof framing will need to be provided to Building Division staff at the One-Stop Permit Center for specific direction on a particular project.

PERMIT PROCESS

1. Prior to submittal for a building permit, contact the Planning Division to determine if a separate permit is required.

Building Permit Review

2. Building permits for most re-roofs are available on-line at www.e-OneStop.net or at the One-Stop Permit Center. The One-Stop Permit Center is open between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Inspections

3. All re-roofs require the following two inspections:
 - An in-progress inspection to verify the ventilation, flue clearance, and material installation. An approved ladder shall be provided for use by the inspector. Following is the stage when this inspection should be scheduled:
 - Composition - All plywood nailed down, 1/2 felted with valleys felted and flashing over felt. Courses started. Drip edge at all rakes installed over felt.
 - Tar and Gravel/Foam - All areas cleaned of debris and new materials on site for inspection.
 - Tile - Furring members in place with approved fireblocking.
 - Shake - Rating of shakes identified, courses started, and felt and flashing in place.
 - The final inspection is required after all work is complete. An extension ladder that extends a minimum of 3' beyond the roof eave shall be made available for the inspector. The following items will be checked at the final inspection:
 - Spark arrester is installed
 - Overflow drains are cleaned
 - Skylights are secured
 - Flues are to be extended and secured
 - Flues and vents are painted to match the color of the roof material
 - Any roof equipment and/or piping is secured
 - Exposed nails are protected and caulked with silicon
 - All exposed wood, roof jacks, and metal flashing or edging are painted
 - Installed gutters are provided with means to prevent accumulation of leaves or debris.

Building Permit Application Requirements

- A completed Building Permit Worksheet application (available at the One-Stop Permit Center or on-line at www.SunnyvaleBuilding.com) - *only one copy of this item needed*
- An approval letter from the Homeowner's Association (if applicable).
- Fee _____