



**Sunnyvale Department of Public Safety**

**FIRE PREVENTION UNIT**



**COMMERCIAL COOKING APPLIANCES**  
**-Securing Equipment-**

- Commercial cooking appliances with suppression system nozzles shall be secured to the floor using pipe stands / floor flanges or other approved method. *See attached photographs*
- The purpose is to prevent the appliance from being moved out of position from the discharge nozzle fixed locations. At least two pipe stands / floor flanges or other approved methods shall be installed.

City of Sunnyvale - Department of Public Safety  
Fire Prevention & Hazardous Materials  
408/730-7212  
*FirePrevention.inSunnyvale.com*

7/19/2010