



Sunnyvale Department of Public Safety

FIRE PREVENTION UNIT



FIRE SPRINKLERS
-Discharge of Test Water-

- New facilities: Water from sprinkler system tests shall be discharged into the sanitary sewer.
- Existing facilities: Sanitary system discharge is preferable. If sanitary is not available, landscape area is acceptable.
- Do not discharge into the storm drain!

(Per D.P.W., Environmental Division, December, 2007)

City of Sunnyvale - Department of Public Safety
Fire Prevention & Hazardous Materials
408/730-7212
FirePrevention.inSunnyvale.com

5/21/2010