



Sunnyvale Department of Public Safety



FIRE PREVENTION UNIT

**HIGHRISE
-EQUIPMENT ROOM LIST -**

PRIMARY HOSE PACK – (Qty. - 1 pack for each equipment room)

Each pack consists of the following:

Quantity	Description/Brand	Part Number (LN Curtis)
4	Hose - Duraflow – 2.5" x 50'- 2.5" NH Coupling Light weight – red	DF825X50R25NH NAFH
1	Gated Wye – TFT 2.5 x 2.5 <u>with</u> gauge	TFT AY5NJ-NJ
1	Nozzle – TFT nozzle pistol grip 2.5" inlet, 1.5" outlet, with 1 ¼" smooth bore straight tip	H-VITG 25
1	Nozzle – Smooth bore straight tip 1 1/8"	FSS-10
1	Nozzle – Smooth bore straight tip 1"	FSS-9
1	Spanner wrench - Akron 10	10 AKR

ATTACK HOSE PACK – (Qty. - 1 pack for each equipment room)

Each pack consists of the following:

Quantity	Description/Brand	Part Number (LN Curtis)
2	Hose - Durabuilt 3.0" X 50' double jacket - 2 ½" couplings– yellow	DBS830X50Y25NH NAFH
1	Gated Wye – TFT 2.5" x 2.5" light weight – <u>without</u> gauge	TFT AY5NJ -NJ
1	Spanner wrench - Akron 10	10 AKR

BACKPACK HOSE PACK – (Qty. - 1 pack for each equipment room)

Each pack consists of the following:

Quantity	Description/Brand	Part Number (LN Curtis)
2	Hose - Durabuilt 1.75" X 50' double jacket – red color	DBS17X50R15NH
1	Nozzle – TFT 1.5" inlet, 1.5" outlet, pistol grip, with 1 ¼" smooth bore integrated straight tip	H-VITG 15
1	Nozzle – Smooth bore straight tip 1 1/8"	FSS-10
1	Nozzle – Smooth bore straight tip 1"	FSS-9
1	Reducer/Adapter – 2.5" to 1.5", TFT Shaped Adapter	H-A
1	Spanner wrench - Akron 10	10 AKR

- Continued on page 2 -



Sunnyvale Department of Public Safety



FIRE PREVENTION UNIT

**HIGHRISE
-EQUIPMENT ROOM LIST -**

ADDITIONAL ITEMS (*quantity is for each equipment room*):

Quantity	Description/Brand	Part Number (LN Curtis)
1	Halligan Tool – 30” Probar (no ring)	PB30 Fire Hooks
1	Pick Head Axe – 6# with 36” Fiberglass Handle	6PH36F
1	Flat Head Axe - 6# with 36” Fiberglass Handle	6FH36F
1	Pike Pole – 8’ Fiberglass with aluminum ‘D’ grip	YPDH8A NUP
1	Little Giant Ladder – Model 13 Type 1A	10101 Little Giant
4	Door Stops – Wedge kit	600275 TMPST
4	Salvage Covers – 14 oz vinyl size 18’ x 24’ - red	#14V Gosport Custom
1	Transfer Flat (<u>for buildings under 150’</u>) – Graham Megamover	http://online.boundtree.com/store/product_index.asp?Cat=&SubCat=&Prod=111500
1	Evacuation Chair (<u>for buildings 150’ or taller</u>) – Striker brand – model #5253	http://evacuation.stryker.com/product/index.htm
1	Married Iron “Milwaukee Strap” Iron Sling	IRS-125
42	Hose strap assemblies – 23” total length, increase by .5”	Custom made – Bruce’s Custom Covers, 989 E. California Ave, Sunnyvale CA 408-738-3959
6	Hose strap assemblies – 27” total length	Custom made – Bruce’s Custom Covers, 989 E. California Ave, Sunnyvale CA 408-738-3959
1	Storage rack for each room – 4 shelves – Capable of holding the weight of the hose packs and smaller equipment.	

16.54.070. Sunnyvale Municipal Code - Fire department equipment rooms.

Approved storage rooms shall be provided at intervals of every fifth story beginning with the third story above fire department building access. Equipment storage rooms shall generally be located inside vestibules or rooms within close proximity to a stairway enclosure, or as approved. Equipment rooms shall be of one hour construction. The fire code official shall determine the amount and type of equipment to be supplied based upon the size, configuration and location of the structure. The equipment shall be purchased by the developer or owner and shall meet the equipment specifications for current in-service equipment utilized by the department of public safety. The equipment shall be maintained at the expense of the owner in accordance with fire code official guidelines.

City of Sunnyvale - Department of Public Safety
Fire Prevention & Hazardous Materials
408/730-7212
FirePrevention.inSunnyvale.com