

**CITY OF SUNNYVALE
PUBLIC WORKS DEPARTMENT/ENGINEERING DIVISION**

ABANDONMENT NOTES:

1. ABANDON UN-USED EXISTING SANITARY SEWER LATERAL IN PLACE FROM BACK OF THE CURB TO THE MAIN. SEAL UN-USED PIPE(S) AT THE BACK OF THE CURB PER GREEN BOOK SECTION 306-5 AND/OR TO THE CITY'S SATISFACTION. FILL THE UN-USED PIPE WITH SAND OR MATERIAL APPROVED BY THE CITY WHERE APPLICABLE. REMOVE AND DISPOSE UN-USED PIPES BETWEEN THE CURB AND THE RIGHT-OF-WAY.
2. ABANDON UN-USED EXISTING WATER SERVICE LINES IN PLACE FROM FACE OF THE CURB TO THE MAIN. SEAL UN-USED PIPE(S) AT THE MAIN AND AT THE BACK OF THE CURB PER GREEN BOOK SECTION 306-5 AND/OR TO THE CITY'S SATISFACTION. REMOVE AND DISPOSE OF UNUSED PIPES BETWEEN CURB AND RIGHT-OF-WAY WITH THE EXCEPTION OF AC PIPE. ASBESTOS CEMENT PIPE SHALL BE ABANDONED IN PLACE. FOR SERVICE LINE LARGER THAN 2" DIA., CONTRACTOR SHALL POTHOLE, CUT OUT LEAD JOINT "T" AT THE MAIN AND REPLACE WITH CLASS 52 DIP WITH TWO SOLID FUSION EPOXY COATED DIP SLEEVES WITH TRIPAC, FLOUROPOLYMER COATED ACCESSORIES (OR REPLACE WITH C900 CLASS 200 PVC WITH TWO SOLID FUSION EPOXY COATED SLEEVES WITH 316 STAINLESS STEEL OR TRIPAC, FLOUROPOLYMER COATED ACCESSORIES FOR PVC PIPES). FOR SERVICE LESS THAN 2" DIA., CONTRACTOR SHALL POTHOLE, CUT OUT AND REMOVE THE CORPORATION STOP AND SADDLE, AND INSTALL FULL CIRCLE 316 STAINLESS STEEL REPAIR CLAMP WITH 316 ACCESSORIES OVER THE HOLE. CONTACT CITY FIELD SERVICES DIVISION TO CHECK THE CONDITION OF THE EXISTING SERVICES PRIOR TO ABANDONMENT.
3. SALVAGE AND ARRANGE THE EXISTING FACILITIES (I.E., METERS, VALVES, ETC.) TO BE PICKED UP BY THE CITY'S FIELD SERVICES DIVISION.
4. ABANDON UN-USED EXISTING UTILITY SERVICE LINES BY OTHERS.
5. SEE DEMOLITION PLANS FOR REMOVAL OF ON-SITE IMPROVEMENTS.